



Adequate ventilation should be provided to the underfloor void using one Rackham Ventilator per 3.0 metres of external wall/

Cavity to be a minimum of 150mm below lowest DPC, 225mm to NHBC requirement.

**All construction details to be in accordance with current Building Regulations and/or NHBC requirements.**